

# ***Annual Drinking Water Quality Report for 2016***

## **Village of Corinth**

244 Main Street, Corinth, NY 12822

(Public Water Supply Identification Number NY4500164, NY4511621, and NY4511622)

### **INTRODUCTION**

To comply with State regulations, the Village of Corinth, will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to New York State standards. Our constant goal is and always has been, to provide to you a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and to protect our water resources. If you have any questions concerning this report or concerning your drinking water please contact: *Mr. Gary Holmes, Head Operator, Village of Corinth, 244 Main Street, Corinth, NY 12822; Telephone (518) 654-6223.* We want our valued customers to be informed about their water service. If you want to learn more, please attend any of our regularly scheduled Village Board meetings. They are held the 1<sup>st</sup> and 3<sup>rd</sup> Wednesday of each month, 6:00 PM at the *16 Saratoga Avenue Firehouse, Telephone (518) 654-2012.*

### **WHERE DOES OUR WATER COME FROM?**

The Village of Corinth draws its water from two drilled wells located on Hamilton Avenue. Well #1 represents the primary production well for the Village water supply and consists of a drilled well 71-feet in depth with an 18-inch casing. The well was developed and first used by the Village in 1963. Well #2 was developed in 1992 and consists of a drilled well 73-feet in depth with an 18-inch casing. Pumping capacity for each well is approximately 825 gallons per minute. Treatment of the raw water produced by the wells consists of gas chlorination, which is used for disinfection to protect against contamination from harmful bacteria and other organisms. We have a 500,000-gallon concrete storage tank located on County Route 10 West Mountain Road to meet consumer demand and provide adequate fire protection.

The source water assessment performed by the New York State Health Department has rated our source water as having an elevated susceptibility to microbial contamination and nitrates. It should be noted that the SWAP looks at the untreated water only. Our water is treated to minimize the potential sources of contamination. The SWAP summary for our water supply is attached to this report.

The Village of Corinth operates a water treatment plant to treat its water that utilizes micron cartridge filters and chlorination. After the water is filtered it flows to a 90,000 gallon clearwell foundation under the filtration plant for chlorine mixing and proper contact time to adequate disinfection.

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and EPA prescribe regulations, which limit the amount of certain contaminants in water, provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

### **FACTS AND FIGURES**

We provide water through 1,571 service connections in Village of Corinth that includes 377 service connections outside the district to a combined population of approximately 4,000 people. In 2016 the Village pumped 186,148,000 gallons of water. Our average daily demand is 508,601 gallons. Our single highest day was 766,000 gallons. Water services are not metered. Customers inside the Village pay \$311.00 per unit while customers outside the Village pay \$437.00 per unit for their water.

### **ARE THERE CONTAMINANTS IN OUR DRINKING WATER?**

In accordance with State regulations, the Village of Corinth routinely monitors your drinking water for numerous contaminants. We test your drinking water for inorganic contaminants, radiological contaminants, lead and copper, nitrate, volatile organic contaminants, and synthetic organic contaminants. In addition, we test 5 samples for coliform bacteria monthly. The table on page 4 depicts which contaminants were detected in your drinking water. The state allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old and is noted. For a listing of the parameters we analyzed that were not detected along with the frequency of testing for compliance with the NYS Sanitary Code, see Appendix A.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the New York State Department of Health Glens Falls District Office at (518) 793-3893.

**WHAT DOES THIS INFORMATION MEAN?**

As you can see by the table on page 4, our system had no violations. We have learned through our monitoring and testing that some constituents have been detected; however, these compounds were detected below New York State requirements. MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

**IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

During 2016, our system was in compliance with applicable State drinking water operating and reporting requirements. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During 2016, we "did not monitor or test" or "did not complete all monitoring or testing" only 15 of the 20 lead and copper sample sites qualified as Tier 1, 2 or 3 and therefore cannot be sure of the quality of your drinking water during that time. We were issued a monitoring violation for failure to collect the required 20 samples.

**DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbiological pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

**INFORMATION ON LEAD**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Corinth is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

**WATER CONSERVATION TIPS**

There are a lot of things you can do to conserve water in your own home. The following tips may alert you to serious water wasting habits many of us have fallen into.

- ◆ Only run the dishwasher and clothes washer when there is a full load.
- ◆ Use water saving showerheads.
- ◆ Install faucet aerators in the kitchen and the bathroom to reduce the flow from 4 to 2.5 gallons per minute.
- ◆ Water gardens and lawn for only a couple of hours after sunset.
- ◆ Residents should report any noises of running water that they cannot find.

**CAPITAL IMPROVEMENTS**

The following projects were completed in 2016:

- ◆ Installed 2,700 feet of new 8 inch ductile iron class 52 ductile water pipe on Ash Street with all new ¾ inch K copper services

**CLOSING**

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit our customers. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have questions.

**VILLAGE OF CORINTH DETECTED CONTAMINANTS  
Public Water Supply Identification Number NY4500164**

Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b> (samples from 2/1/16 unless otherwise noted)						
Chloride	N	18.5	ppm	N/A	250	Geology; Naturally occurring
Copper (samples from 6/7/16-6/8/16) Range of copper concentrations	N	0.80 <sup>1</sup> 0.11-0.94	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead (samples from 6/7/16-6/8/16) Range of lead concentrations	N	4 <sup>2</sup> ND-7	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate	N	0.266	ppm	10	10	
pH	N	7.12	units		6.5-8.5	
Sodium <sup>3</sup>	N	11	ppm	N/A	N/A	Geology
Sulfate	N	5.72	ppm	N/A	250	Geology
Zinc	N	28	ppb	N/A	5000	Galvanized pipe; <b>corrosion inhibitor</b>
<b>Stage 2 Disinfection Byproducts</b> (samples from 8/1/16)						
Total Trihalomethanes 421 Mill Street	N	17.2	ppb	0	80	By-product of drinking water chlorination
Total Trihalomethanes Eastern Ave WD	N	10.8				
Haloacetic Acids 421 Mill Street	N	4.9	ppb	N/A	60	By-product of drinking water chlorination
Haloacetic Acids Corinth Homes WD	N	0.59				
Haloacetic Acids Eastern Ave WD	N	3.1				
Chlorine Residual (average) (range) (based on daily samples)	N	0.82 0.19-1.94	ppm	MRDLG N/A	MRDL 4	By-product of drinking water chlorination
<b>Microbiological Contaminants</b>						
Turbidity (sample from 3/16/16)	N 100%	0.45 <sup>4</sup>	NTU	N/A	TT=5 TT=95% of samples <1.0	Soil runoff

**FOOTNOTES-**

- The level presented represents the 90<sup>th</sup> percentile of 20 test sites. The action level for copper was not exceeded at any of the 20 sites tested in June 2016.
  - The level presented represents the 90<sup>th</sup> percentile of 20 test sites. The action level for lead was not exceeded at any of the 20 sites tested in June 2016.
  - Water containing more than 20 mg/l should not be consumed by persons on severely restricted sodium diets.
  - Turbidity is a measure of the cloudiness of the water. We are required to monitor turbidity in the interim 5 times a week from the distribution system and we had the highest turbidity of 3.37 NTU on 7/3/15 with an average of 0.14 NTU.
- Non-Detects (ND)* - laboratory analysis indicates that the constituent is not present.
- Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.
- Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- Picocuries per liter (pCi/L)* - picocuries per liter is a measure of the radioactivity in water.
- Action Level* - the concentration of a contaminant, which, if exceeded, triggers treatment, or other requirements, which a water system must follow.
- 90<sup>th</sup> Percentile Value*- The values reported for lead and copper represent the 90<sup>th</sup> percentile. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the lead and copper values detected at your water system.
- Maximum Contaminant Level* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal* The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Residual Disinfectant Level (MRDL)*: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG)*: The level of a drinking water disinfectant below which there is no known or expected risk to health.
- Locational Running Average (LRAA)* - The LRA is calculated by taking the average of the four most recent samples collected at each individual site.
- N/A-Not applicable*

**Appendix**

New York State Sanitary Code Compliance Monitoring Requirements- Compounds Analyzed that were Below Limits of Detection

VILLAGE OF CORINTH TEST RESULTS Public Water Supply Identification Number NY4500164				
CONTAMINANT	MONITORING FREQUENCY		CONTAMINANT	MONITORING FREQUENCY
Asbestos	1 sample every 9 years Sample from 5/2/11 <b>Non-Detect</b>		<b>POC's (Volatile Organic Compounds)</b>	
			Benzene	Trans-1,3-Dichloropropene
			Bromobenzene	Ethylbenzene
			Bromochloromethane	Hexachlorobutadiene
Antimony	Monitoring requirement is 1 sample every year  <b>Non-Detect</b> Sample from 2/1/16		Bromomethane	Isopropylbenzene
Arsenic			N-Butylbenzene	p-Isopropyltoluene
Barium			sec-Butylbenzene	Methylene Chloride
Beryllium			Tert-Butylbenzene	n-Propylbenzene
Cadmium			Carbon Tetrachloride	Styrene
Chromium			Chlorobenzene	1,1,1,2-Tetrachloroethane
Cyanide			2-Chlorotoluene	1,1,2,2-Tetrachloroethane
Mercury			4-Chlorotoluene	Tetrachloroethene
Selenium			Dibromomethane	Toluene
Thallium			1,2-Dichlorobenzene	1,2,3-Trichlorobenzene
Fluoride			1,3-Dichlorobenzene	1,2,4-Trichlorobenzene
Nickel			1,4-Dichlorobenzene	1,1,1-Trichloroethane
Silver			Dichlorodifluoromethane	1,1,2-Trichloroethane
			1,1-Dichloroethane	Trichloroethene
			1,2-Dichloroethane	Trichlorofluoromethane
			1,1 Dichloroethene	1,2,3-Trichloropropane
Color		Monitoring requirement is at State discretion  <b>Non-Detect</b> Samples from 2/1/16		cis-1,2 Dichloroethene
Iron			Trans-1,2-Dichloroethene	1,3,5-Trimethylbenzene
			1,2 Dichloropropane	m-Xylene
Manganese			1,3 Dichloropropane	o-Xylene
Odor			2,2 Dichloropropane	p-Xylene
			1,1 Dichloropropene	Vinyl Chloride
			Cis-1,3-Dichloropropene	MTBE
			Total Coliform	
			E. coli	
Turbidity Entry Point	N/A			<b>Radiological Parameters</b>
			Gross Alpha	Quarterly Samples 2/4/13
			Radium 226 , Radium 228	
Regulated & Unregulated Synthetic Organic Chemicals				
Synthetic Organic Chemicals (Group I)		Synthetic Organic Chemicals (Group II)		
Alachlor	Aldicarb		Aldrin	Monitoring requirement is one sample every 18 months  <b>Non-Detect</b> Sample from 4/4/16 <b>*State waiver does not require monitoring these compounds</b>
Aldicarb Sulfoxide	Aldicarb Sulfone		Butachlor	
Atrazine	Carbofuran		Dalapon	
Chlordane	Dibromochloropropane		Di(2-ethylhexyl)phthalate	
2,4-D	Endrin		Dicamba	
Ethylene Dibromide	Heptachlor		Dinoseb	
Lindane	Methoxychlor		Diquat*	
PCB's	Toxaphene		Endothal*	
2,4,5-TP (Silvex)			Glyphosate*	
			Hexachlorobenzene	
			Hexachlorocyclopentadiene	
			3-Hydroxycarbofuran	
			Methomyl	
			Metolachlor	
			Oxamyl vydate	
			Propachlor	
			Simazine	
			2,3,7,8-TCDD (Dioxin)*	

**Corinth Village**  
**NY45001 64**  
**Source Water Assessment Summary**

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how rapidly contaminants can move through the subsurface to the wells. The susceptibility of a water supply well to contamination is dependent upon both the presence of potential sources of contamination within the well's contributing area and the likelihood that the contamination can travel through the environment to reach the well. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

The source water assessment has rated our water source as having an elevated susceptibility to microbials and nitrates. These ratings are due primarily to close proximity of the wells to permitted discharge facilities (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state and/or federal government) and the associated industrial activity in the assessment area. In addition, the wells are located in an area which is prone to flooding. While the source water assessment rates our wells as being susceptible to microbials, please note that our water is disinfected to ensure that that the finished water delivered into your home meets New York State's drinking water standards for microbial contamination.

The county and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning and education programs.

A copy of the full Source Water Assessment, including a map of the assessment area, is available for review by contacting us at the number provided in this report.